

ZHEJIANG HENGSHENG FIRE EQUIPMENT CO.,LTD.

ADD:TAOJIA FAN,PINGSHUI STREET VILLAGE, PINGSHUI TOWN, SHAOXING COUNTY, ZHEJIANG PROV., CHINA

TEL: 0086-575-85723368. FAX:0086-575-85768320

FIRE HOSE INSPECTION REPORT

Product: white color canvas fire hose, Black pvc lined			Commodity: lined fire hose	
Manufactured Date: March, 2022			Size: 13bar-65mm-20m	
Tested hose No.: HS20220128			Selective Test: 8rolls	
QTY.: 250 rolls				
NO.	Item	Requirement	Inspection Result	Conclusion
1	Visual	Plain weave, clean surface, no knots, no lumps, no hurts etc.	OK	PASS
2	Internal Diameter (mm)	63.5-66.5	65	PASS
3	Lining Quality	Equal thickness, smooth and flat, no ridge, no other defects	OK	PASS
4	Lining Thickness	0.40mm	OK	PASS
5	Mass per unit length	≤480g/m	295g	PASS
6	Length (m)	20.0+0.2	20.1	PASS
7	Adhesion Strength (N/25mm)	≥25	35	PASS
8	Burst Pressure (MPa)	≥4.5	4.8	PASS
9	Leak	No leakage under hydraulic	OK	PASS
10	Elongation Rate (%)	≤5	2.3	PASS
11	Swell Rate (%)	≤5	3.7	PASS
Conclusion		PASS	Remark	

浙江恒胜消防设备有限公司  
ZHEJIANG HENGSHENG FIRE EQUIPMENT CO., LTD.

张黎